

GENERICA

КРОНШТЕЙН АНКЕРНЫЙ ТИПА КАМ-1500

Краткое руководство по эксплуатации

UKA.KAM.G.001.2

RU Основные сведения об изделии

Кронштейн анкерный типа КАМ-1500 (далее – кронштейн) товарного знака GENERICA предназначен для крепления зажимов магистральных и абонентских линий ВЛИ, выполненных самонесущими изолированными проводами (СИП) и ВЛ, выполненных самонесущими неизолированными проводами (СНП), на деревянных, железобетонных и металлических опорах, а также на стенах зданий и сооружений.

Условия эксплуатации кронштейна:

- рабочий диапазон температур от минус 60 до плюс 55 °С при относительной влажности воздуха до 95 %. Допускается эксплуатация кронштейна при температуре окружающей среды до плюс 80 °С и относительной влажности 60 %;
- вид климатического исполнения по ГОСТ 15150 – УХЛ1.

Меры безопасности

ВНИМАНИЕ

До начала работ принять меры безопасности, исключающие монтаж ВЛИ и (или) ВЛ под напряжением/потенциалом.

Кронштейн ремонту не подлежит. При выходе из строя кронштейн подлежит утилизации. По истечении срока службы кронштейн подлежит утилизации.

Правила монтажа

Монтаж ВЛИ и(или) ВЛ должен производить квалифицированный персонал, прошедший обучение в специализированной организации с присвоением группы по электробезопасности не ниже III до 1000 В при температуре окружающей среды не менее минус 10 °С.

При монтаже следует предпринять меры, исключающие возможность падения кронштейна с высоты.

Во время монтажа не допускать ударов по кронштейну молотком или другими массивными металлическими предметами.

Комплектность

В комплект поставки входит:

- кронштейн – 10шт.;
- паспорт – 1 экз. на упаковку.

GENERICA

Транспортирование, хранение и утилизация

Транспортирование кронштейна должно производиться в закрытом транспорте в упаковке изготовителя в соответствии с правилами, действующими на конкретном виде транспорта, при температуре окружающего воздуха от минус 50 до плюс 50 °С и относительной влажности 75 % при 15 °С. Условия транспортирования в части воздействия механических факторов по группе С и Ж по ГОСТ 23216.

Хранение кронштейна осуществляется только в упаковке изготовителя в помещениях с естественной вентиляцией при температуре окружающего воздуха от минус 60 до плюс 80 °С и относительной влажности 75 % при 15 °С, допускается хранение при относительной влажности 100 % при 25 °С.

При транспортировании и хранении кронштейны в упаковке должны быть уложены на деревянные поддоны или на сухие и ровные поверхности. Допускается хранение и транспортирование упакованных кронштейнов без использования поддонов. Попадание под штабель посторонних предметов, воды и горюче-смазочных материалов не допускается.

В процессе транспортирования и хранения кронштейн не должен подвергаться воздействиям механических нагрузок, ударов, воды и прямого солнечного света.

Для утилизации сдать кронштейн в специализированную организацию по приёмке и переработке вторсырья.

Срок службы и гарантии изготовителя

Гарантийный срок эксплуатации кронштейна – 6 лет, при соблюдении потребителем правил эксплуатации, монтажа, транспортирования и хранения.

Срок службы кронштейна – не менее 40 лет.

EN Basic product data

The KAM-1500 type anchor bracket (hereinafter referred to as the bracket) of the GENERICA trademark is designed for attaching clamps of main and drop overhead power lines made of self-bearing isolated wires (SIW) and overhead power lines made of self-bearing bare wires (SBW) on wooden, reinforced concrete and metal poles as well as on building and structure walls.

Operating Conditions:

- the working temperature range is from minus 60 to plus 55 °С with relative air humidity of up to 95%. The bracket can be operated at ambient temperatures of up to plus 80 °С and relative humidity of 60%.

- climatic category – NF1.

GENERICA

Safety measures

ATTENTION

Before starting work, take safety measures to prevent installation of overhead power lines made of self-bearing isolated wires and (or) of self-bearing bare wires under voltage/potential.

The bracket is not subject to repair. If the bracket fails, it must be disposed of. Upon expiration of its service life, the bracket must be disposed of.

Installation rules

Installation of overhead power lines made of self-bearing isolated wires and (or) of self-bearing bare wires must be carried out by qualified personnel who have undergone training in a specialized organization with an electrical safety group assignment of no less than III up to 1000 V at an ambient temperature of at least minus 10 °C.

Measures must be taken during installation to prevent the bracket from falling from a height.

Do not strike the bracket with a hammer or other heavy metal objects during installation.

Completeness of set

The delivery set includes:

- bracket – 10 pcs.;
- passport – 1 copy per package.

Transportation, storage and disposal

The bracket must be transported by covered transport in the manufacturer's packaging according to the rules applicable to the specific mode of transport, at ambient temperatures from minus 50 to plus 50 °C and relative humidity of 75% at 15 °C.

Storage of the bracket is only allowed in the manufacturer's packaging in premises with natural ventilation at ambient temperatures from minus 60 to plus 80 °C and relative humidity of 75% at 15 °C. Storage at relative humidity of 100% at 25 °C is permissible

During transportation and storage the brackets in packaging should be placed on wooden pallets or dry, flat surfaces. Storage and transportation of packaged brackets without pallets are permitted. The presence of foreign objects, water and lubricants under the stack is not allowed.

The bracket must not be subjected to mechanical loads, impacts, water or direct sunlight during transportation and storage.

For disposal, hand the bracket over to a specialized recycling organization.

GENERICA

Service life and manufacturer's warranties

The warranty period of bracket operation is 6 years provided the consumer complies with rules of operation, installation, transportation and storage.

The service life of the bracket is at least 40 years.

Габаритные размеры / Overall dimensions

